

DISTRICT LEVEL WATER TESTING LABORATORY P.H.DIVISION, MADHUBANI

DISTRICT- MADHUBANI

Sample Collected by & Submitted by:- Santosh kr Jha

Sampling Date:- 06/01/2025
Testing Date:-07/01/2025
Months:- January 2025

Sl No.	Block	Panchayat	Village	Source of Water	Name of Location/Nearst Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	SO4	NO3	TDS	EC	AS	MPN	Remarks
1	Rajnagar	Ranti	Ranti	Tubewell 1	Sushila Educational Institute	7.5	1.2	200	262	56	20	60	0.21	0.18	Nil	0.5	437	672	NT	A	
2	Rajnagar	Ranti	Ranti	Tubewell 2	Sushila Educational Institute	7.5	1.5	204	280	56	20	60.5	0.2	0.17	Nil	0.5	426	655	NT	A	
3	Rajnagar	Ranti	Ranti	R.O	Sushila Educational Institute	7.5	1	206	232	55.2	19.71	59	0.18	0.15	Nil	0.4	426	654	NT	A	
Min-Max-Permissible Limit																					
						6.5 - 8.5	1.0-0.5	200 - 600	200 - 600	75 - 200	30 - 100	250 - 1000	1.0	0.5 - 1.5	200 - 400	45	500 - 2000		0.01 - NR		

*A - Absent
*NT - Not Tested

NOTE:- THIS REPORT IS VALID FOR 6 MONTHS FROM THE DATE OF TESTING.



Principal
Sushila Educational Institute
Ranti, Madhubani

Santosh Kr Jha
07 Jan. 2025
Lab Analyst
District Laboratory, Madhubani